

DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) Nr.305/2011

Nr. 1922-CPR-2474

1. Unique identification code of the product-type

Fire detection and fire alarm systems. Manual call points models: *SPR-3L*

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11 (4):

***SPR-3L*, batch number see product label**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire safety

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11 (5):

PC "ARTON", 6 Prutska str., 58008, Chernivtsi, Ukraine

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

«Dedal Attestation & Certification» Ltd

performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the following certificate of constancy of performance:

Nr. 1922-CPR-2474

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9. Declared performance

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been described in the hEN mentioned in the following tab

Essential characteristic	Performance	Clause
Nominal activation conditions /Sensitivity and Performance underfire conditions		
<i>Alarm condition</i>	Pass	4.3.2
<i>Indicators for alarm condition</i>	Pass	4.4
<i>Safety aspects</i>	Pass	4.7.1
<i>Protection against accidental operation</i>	Pass	4.7.4
<i>Operational performance test</i>	Pass	5.2
<i>Function test</i>	Pass	5.3
Operational reliability		
<i>Marking and data</i>	Pass	4.2
<i>Normal condition</i>	Pass	4.3.1
<i>Reset facility</i>	Pass	4.5
<i>Testfacility</i>	Pass	4.6
<i>Shape, dimensions and colours</i>	Pass	4.7.2
<i>Symbols and lettering</i>	Pass	4.7.3
<i>Environment category</i>	Pass	4.7.5
<i>Additional requirements for software controlled manual call points</i>	N/A	4.8
<i>Test facility test (operational)</i>	Pass	5.4
<i>Reliability test (endurance)</i>	Pass	5.5
Durability of operational reliability, temperature resistance		
<i>Dry heat (operational)</i>	Pass	5.7
<i>Dry heat (endurance)</i>	NPD	5.8
<i>Cold (operational)</i>	Pass	5.9
Durability of operational reliability, vibration resistance		
<i>Shock (operational)</i>	Pass	5.14
<i>Impact (operational)</i>	Pass	5.15
<i>Vibration, sinusoidal (operational)</i>	Pass	5.16
<i>Vibration, sinusoidal (endurance)</i>	Pass	5.17
Durability of operational reliability, humidity resistance		
<i>Damp heat, cyclic (operational)</i>	Pass	5.10
<i>Damp heat, cyclic (endurance)</i>	NPD	5.11
<i>Damp heat, steady state (endurance)</i>	Pass	5.12
<i>Enclosure protection</i>	NPD	5.19
Durability of operational reliability, corrosion resistance		
<i>Damp heat, cyclic (endurance)</i>	NPD	5.11
<i>Sulphur dioxide (SO2) corrosion (endurance)</i>	Pass	5.13
Durability of operational reliability, electrical stability		
<i>Variation of supply parameters</i>	Pass	5.6
<i>Electromagnetic compatibility (FMC), (operational)</i>	Pass	5.18

Where pursuant to Article 37 or 38 the Specific Technical Documentation has been used, the requirements with which the product complies:

Not applicable

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.


This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Mr. Vladyslav Bondarenko,
director

Chernivtsi, 01.12.2025

Signature



(Handwritten signature)